

FIRMWARE UPDATE MANUAL


SmartGen Micro




Firmware updating using USB port

1. Connect your PC directly to SmartGen Micro via USB cable.
2. Start “DEVA BootLoader.exe”.
3. Click on “Open Firmware” button and select the file with SmartGen Micro firmware update (the one with “*.bin” extension).
4. Check “USB” Interface Radio Button.


The screen looks like the one shown below:



5. Turn OFF SmartGen by unplugging the Power Cord.
6. Click on “Find Device” button.
7. Plug-in the device Power Cord when you see “*Searching Device... Please turn OFF the device for 5 seconds.*” in Process Information area. The Device will power on and will be recognized by the Boot Loader software.
8. Click on “Program” button to start the updating process. This is indicated by the progress indicator and in Progress Information area. The screen will look as the one shown below:



9. Firmware Upgrade completion is indicated by the progress indicator and in Process Information area as shown on the picture below:



10. Wait for the process completion and close the window.